



NOTES:

1. MANHOLE RISER SHALL BE CAST MONOLITHICALLY WITH 8" LG. PIPE SECTION.
2. FLEXIBLE BUTYL RUBBER SEALANT EQUAL TO CONSEAL TYPE CS-302 SHALL BE USED TO: SEAL CASTING TO MANHOLE, SEAL ADJUSTING RINGS TOGETHER AND TO RISERS, AND TO SEAL MANHOLE RISER JOINTS. THE SEALANT MUST BE APPLIED TO THE OUTSIDE AND INSIDE HORIZONTAL PORTION OF EACH MANHOLE JOINT.

NO SCALE



CLERMONT COUNTY
SEWER DISTRICT

APPROVED _____
DATE _____

STANDARD MANHOLE
FOR SEWERS
42" & LARGER

DRAWING NO.

S1.3